



FINAL REPORT

VIRUS FILTRATION EFFICIENCY TEST (VFE)  
AT AN INCREASED CHALLENGE LEVEL

PROCEDURE NO. STP0010 REV 03

LABORATORY NO. 500235

PREPARED FOR:

LÁSZLÓ CSATAR  
PISTON LTD.  
SZÖLÖKERT UTCA 4/B.  
BUDAPEST H-1033  
HUNGARY

SUBMITTED BY:

NELSON LABORATORIES, INC.  
6280 S. REDWOOD RD.  
SALT LAKE CITY UT 84123-6600  
801-290-7500

VIRUS FILTRATION EFFICIENCY TEST (VFE)  
AT AN INCREASED CHALLENGE LEVEL

|                            |   |
|----------------------------|---|
| LABORATORY NUMBER:         | 500235                                      |
| PROCEDURE NUMBER:          | STP0010 REV 03                              |
| SAMPLE SOURCE:             | Piston Ltd.                                 |
| SAMPLE IDENTIFICATION:     | Refer to Table 1<br>P.O. #CsL-PO-046-2-2009 |
| DEVIATIONS:                | None  |
| SAMPLE RECEIVED DATE:      | 02 Nov 2009                                 |
| LAB PHASE START DATE:      | 24 Nov 2009                                 |
| LAB PHASE COMPLETION DATE: | 30 Nov 2009                                 |
| REPORT ISSUE DATE:         | 01 Dec 2009                                 |

INTRODUCTION:

This report describes the procedure and results of the virus filtration efficiency (VFE) at increased challenge level testing. This procedure was performed to determine the filtration efficiency of the test materials using a ratio of the challenge to effluent to determine percent efficiency. This procedure allowed a reproducible aerosol challenge to be delivered to each of the test materials. This test procedure was modified from Nelson Laboratories, Inc., standard VFE test and employed a more severe challenge than would be expected in normal use. This method was adapted from ASTM F2101.

ACCEPTANCE CRITERIA:

The mean particle size (MPS) of the challenge aerosol was maintained at  $3.0 \pm 0.3 \mu\text{m}$ .

The average percent virus filtration efficiency (%VFE) for the reference material was within the upper and lower control limits established for the VFE test.

The VFE challenge level was  $\geq 1 \times 10^6$  PFU/test sample when the flow rate is  $\geq 30$  LPM.

JUSTIFICATION:

This VFE test provides a number of advantages over other filtration efficiency tests. The use of all glass impingers (AGIs) in the collection process allowed a high concentration of challenge to be delivered to each test material. The aerosol challenge particle size can be tightly controlled by monitoring the airflow and challenge flow through the nebulizer. The aerosol particles can be sized using a six-stage viable particle Andersen sampler.

Piston Ltd.  
Lab Number 500235

VFE at an Increased Challenge Level

The  $\Phi$ X174 bacteriophage has a diameter of 25-27 nanometers (nm) (0.025-0.027  $\mu$ m), therefore, provides a severe challenge to the test sample.

#### CHALLENGE PROCEDURE:

The stock bacteriophage  $\Phi$ X174 was prepared by inoculation of  $\Phi$ X174 into a log phase culture of *E. coli*. The culture was shaken at  $37 \pm 2^\circ\text{C}$  until bacterial turbidity cleared. The virus stock was centrifuged to remove large cellular debris and then filtered through a 0.2  $\mu$ m membrane filter to remove remaining host cell debris. The stock culture was stored at 2-8 $^\circ\text{C}$ .

The challenge suspension was pumped through a 'Chicago' nebulizer using a peristaltic pump at a controlled flow rate and fixed air pressure. The constant challenge delivery formed aerosol droplets of defined size. The challenge level was adjusted to provide a consistent challenge of at least  $10^6$  plaque forming units (PFU) per test sample.

The aerosol droplets were generated in a glass aerosol chamber and drawn through the sample holder and into all AGIs in parallel. Each AGI contained 30 mL aliquots of sterile peptone water (PEPW) to collect the aerosol droplets. The aerosol challenge flow rate was maintained at 30 Liters per minute (Lpm).

The challenge was delivered for a 1 minute interval and sampling through the AGIs was conducted for 2 minutes to clear the aerosol chamber. Control runs (no media in sample holder) were performed after every 5-7 test samples to determine the number of viable particles being generated in the challenge aerosol.

The AGI fluid was assayed using standard plaque assay techniques. All plates were incubated at  $37 \pm 2^\circ\text{C}$  for 12-24 hours.

#### RESULTS:

The filtration efficiencies were calculated using the following equation:

$$\% \text{ VFE} = \frac{C - T}{C} \times 100$$

Where: C = Average of control values.  
T = Effluent counts of test material.


The MPS of the challenge aerosol was determined using a six-stage Andersen sampler. The challenge level, MPS, and filtration efficiencies of the samples are summarized in Table 1. Testing met the acceptance criteria previously stated in this report.

Piston Ltd.  
Lab Number 500235

VFE at an Increased Challenge Level

STATEMENT OF UNCERTAINTY:

If applicable, the statement of uncertainty is available to sponsors upon request.



Adrienne Sandall, B.S.  
Study Director

01 Dec 2009  
Study Completion Date

anl

Piston Ltd.  
Lab Number 500235

VFE at an Increased Challenge Level

TABLE 1. VFE Results  
Sample Identification: Bacterial and Viral Filter, Type: PBF-100

| SAMPLE IDENTIFICATION | TOTAL PFU RECOVERED   | FILTRATION EFFICIENCY |
|-----------------------|-----------------------|-----------------------|
| Lot #20091021/6       | <1 <sup>a</sup>       | >99.999947%           |
| Lot #20091021/7       | <1 <sup>a</sup>       | >99.999947%           |
| Lot #20091021/8       | <1 <sup>a</sup>       | >99.999947%           |
| Lot #20091021/9       | 9                     | 99.99952%             |
| Lot #20091021/10      | 2.7 x 10 <sup>1</sup> | 99.9986%              |

Challenge Level (PFU): 1.9 x 10<sup>6</sup> PFU

Mean Particle Size (MPS): 2.8 µm

<sup>a</sup> There were no detected plaques on any of the assay plates for this sample.

Piston Ltd.  
Lab Number 500235

VFE at an Increased Challenge Level

All reports and letters issued by Nelson Laboratories, Inc. are for the exclusive use of the sponsor to whom they are addressed. These results relate only to the samples tested. Reports may not be reproduced except in their entirety. No quotations from reports or use of the corporate name is permitted except as expressly authorized by Nelson Laboratories, Inc. in writing. The significance of any data is subject to the adequacy and representative character of the samples tendered for testing. Nelson Laboratories, Inc. warrants that all tests are performed in accordance with established laboratory procedures and standards. Nelson Laboratories, Inc. makes no other warranties of any kind, express or implied. Nelson Laboratories, Inc. expressly states that it makes no representation or warranty regarding the adequacy of the samples tendered for testing for any specific use of application, that determination being the sole responsibility of the sponsor. Nelson Laboratories' liability for any loss or damage resulting from its actions or failure to act shall not exceed the cost of tests performed, and it shall not be liable for any incidental or consequential damages. Nelson Laboratories, Inc. has a ten year record retention policy.